

40 CFR
280.31C

Underground Storage Tank (UST) systems with impressed current cathodic protection systems must be inspected every 60 days to ensure the equipment is operating properly. (If equipment is equipped with green light on front panel, is the light on? If the equipment is equipped with meters, record the meter readings.)

[illegible]